Release Summary Sheet

Contract (PO) Number: T26477

Release Number: 51

Specification Number: B09688501

Name of Contractor: KENNY CONSTRUCTION CO

City Department: DEPARTMENT OF WATER MANAGEMENT

Title of Contract: T0968850101 WATER TREATMENT SERVICES

Dollar Amount of Release: \$40,090.21

Release Description: WATER AND WASTEWATER TREATMENT SERVICES

WATER - YEAR 2000 (JOB ORDER CONTRACT)

Procurement Services Contact Person: BYRON WHITTAKER

Vendor Number: 456060

Submission Date:

CITY OF CHICAGO BLANKET RELEASE

Original (Department)

Furnish the supplies and/or services described below in conformance with conditions set forth herein and in your offer

RELEASE	PURCHASE	RELEASE	SPECIFICATION NUMBER	VENDOR	SITE	DELIVERY	PAGE
DATE	ORDER	NUMBER		NUMBER	NAME	DATE	NUMBER
07/22/2004	T26477	51	B09688501	456060	Α		1

DELIVER TO:

88-087

087-2045 JARDINE 1000 E. OHIO ST. Chicago, IL 60611 ORDERED FROM:

KENNY CONSTRUCTION CO 250 NORTHGATE PKWY WHEELING, IL 60090

DELIVERY CHARGES to be PREPAID TITLE TO PASS ON DELIVERY

CONTACT:

Richard Patrick 744-5067

PO DESCRIPTION:

T0968850101 WATER TREATMENT SERVICES

BLANKET RELEASE

THIS SIGNED RELEASE IS YOUR AUTHORITY TO FURNISH THE SPECIFIED SUPPLIES AND /OR SERVICES IN ACCORDANCE WITH THE TERMS AND CONDITIONS OF THE BLANKET AGREEMENT NUMBER: T26477

THIS PURCHASE IS FOR DEPARTMENT:

88 - DEPARTMENT OF WATER MANAGEMENT

SUBMIT THE ORIGINAL INVOICE TO:

	1										SHIPMEN	T TOTAL:	40,090.21
		1	000	0205	0872045	0540	220540	W706	99308000	000000	00000	0000	40,090.21
		Dist	BFY	FUND	COST CTR	APPR	ACCNT	ACTV	PROJECT	RPT CAT	GENRL	FUTR	
			WATE	R - YEA	VASTEWATEF R 2000 (JOB C Water Purificat	RDER C	ONTRACT)	ning Add'l Wo	orkscope			
1	1		96896	5.05					40,090.21	USD		1.00	40,090.21
PO Line	Ship Line		COM	MODITY	INFORMATION	N		(QUANTITY	UOM		UNIT COST	TOTAL COST

RELEASE TOTAL:

40,090.21

APPROVAL:

SIGNATURE

DATE

SIGNATURE

DATE

To:

Department of: Water

Date:

05/18/2004

Sub-Order Total:

\$40,090.21

DISCLOSURE OF RETAINED PARTIES

Definitions and Disclosure Requirements.

- 1. As used herein, the term "Contractor" means a person or entity who has any contract or lease with the City of Chicago.
- 2. Pursant to Executive Order 97-1, every city contract and lease must be accompanied by a disclosure statement providing certain information and attorneys. lobbyists, accountants, consultants, subcontractors, and other persons whom the Contractor has retained or expects to retain with respect to the contract or lease. In particular, the Contractor must disclose the name of each such person, his or her business address, the naure of the relationship, and the amount of fees paid or estimated to be paid.
- 3. The Contractor is not required to disclose employees who are paid solely through the Contractor's regular payroll.
- 4. "Lobbyist" means any person (a) who for compensation or on behalf of any person other than himself undertakes to influence any legislative or administrative action, or (b) any part of whose duties as an employee of another includes undertaking to influence any legislative or administrative action.

B. Certification

Contractor hereby certifies as follows:

1. This Disclosure relates to the following transaction:

Project name:

01-02-014A

SWPP - Repair Roof Slab - Tank 721

Specification, loan or other Identifying number: T0968850101

2. Name of Contractor:

Kenny Construction Company

3. EACH AND EVERY attorney, lobbyist, accountant, consultant, subcontractor, or other person retained or anticipated to be retained by the Contractor with respect to or in connection with the contract or lease is listed below (attach additional pages if necessary):

NAME	BUSINESS ADDRESS	RELATIONSHIP (attorney, lobbyist, subcontractor,etc.)	FEE(indicate whether paid \$ or estimated)	

CHECK HERE IF NO SUCH PERSONS HAVE BEEN RETAINED OR ARE ANTICIPATED TO BE RETAINED

- 4. The Contractor understands and agrees that the City may rely on the information provided herein and that providing any flase, incomplete or inaccurance information shall consitute default under the contract and may result in termation of the contract or lease.
- 5. The Contractor understands and agrees that in any case in which the Contractor is uncertain whether a disclosure is required under the Executive Order, the Contractor must either ask the city whether disclosure is required or make the disclosure.

Under penalties of perjury, I certify that I am authorized to execute this Disclosure on behalf of the Contractor that the information disclosed herein is true and complete, and that no relevant information has been withheld.

Date

Project Manager

Title

Subscribed and sworn to before me day of

20 04

Notary Public Signature

\$ "OFFICIAL SEAL" SUSAN STANCZAK Notary Public, State of Illinois My Commission Expires 10/03/07 ********





City of Chicago Richard M. Daley, Mayor

Department of Water Management

Jardine Water Purification Plant 1000 East Ohio Street Chicago, Illinois 60611 (312) 744-7001 (312) 744-7119 (FAX) (312) 744-2968 (TTY) http://www.cityofchicago.org 03 MAY 19 FM 2: 18

Mr. David Malone Chief Procurement Officer Department of Procurement Services Room 400, City Hall 121 North LaSalle Street Chicago, Illinois 60602

SUBJECT: Job Order Contract - Department of Water

Project Description: South Water Purification Plant

Chemical Tank Relining

(Additional Workscope - Repair Roof Slab)

(Tank No.721)

Project No. 01-02-014A Contract No. T0968850101 Spec. No. B09688501

Estimated Cost: \$ 40,000.00

Funding No.: 01-227-87-2045-0540-W706-220540-02305010

Dear Mr. Malone:

This Department is requesting the Contractor to replace the top roof slab on the polymer receiving tank number 721, at the subject location, by completing the following workscope:

- -Temporily support the mechanical agitator that is mounted on the existing concrete roof slab.
- -Install shoring tower inside of tank.
- -Remove and dispose of existing top slab.
- -Furnish and install epoxy coated steel reinforcement bars.
- -Furnish, install, and finish concrete roof slab.
- -Remove shoring tower from inside tank.
- -Re-install mechanical agitator and other applicable appurtenances.
- -Remove and dispose of all construction debris in accordance with all applicable codes and guidelines.

Estimated duration of this Project is Thirty(30) calendar days.

Enclosed is the preliminary estimate of cost for the work involved and a project description. Funding for this work is in place.





If you concur with this request, please notify this office as soon as possible and forward a copy of the approved memorandum of authorization. For any further information concerning this matter, contact Richard Patrick, Bureau of Water Engineering at 744-5067.

Yours truly,

Richard A. Rice Commissioner

Approved By

David Malone

Chief Procurement Officer

RP:rp



Job Order Contract

Department of: Water

Contractor: Kenny Construction

Date:

07 May 2003

Work Order #: 01-02-014A

Work Order Title: SWPP- TANK RELINING(REPAIR TANK ROOF SLAB)

				10 (17.2) 17.2) 17.2) 17.2)	Cost	Estimate	9			
Sect.	item	Mod.	Source	UOM D	Description					Line Total
- 19001	1278			LS T	EMP. SUPP	ORT MECH. AC	SITATOR	(1-2-14A)		2,000.00
				Quantit	ty	Unit Price	Fact.		Total	
			Installation	1.	.00 x	2,000.00 x	1.0000	=	2,000.00	
19001	1279			LS IN	NSTALL SHO	ORING IN TANK	((1-2-14)			4,000.00
			-	Quantit		Unit Price	Fact.		Total	· · · · · · · · · · · · · · · · · · ·
			Installation		.00 x	4,000.00 x	1.0000	=	4,000.00	
19001	1280		 	LS R	REMOVE AN	D DISPOSE OF	EXIST.	SLAB(1-2-14A)		8,000.00
				Quantit		Unit Price	Fact.		Total	
			Installation		.00 x	8,000.00 x	1.0000	=	8,000.00	
19001	1281			LS II	NSTALL REI	NFORCEMENT	BARS(1	-2-14)		4,000.00
				Quantit		Unit Price	Fact.		Total	- inner a second
			Installation	1	.00 x	4,000.00 x	1.0000	=	4,000.00	
19001	1282			LS F	URNISH, IN	STALL AND FI	VISH CO	NC. SLAB(1-2-14	A)	8,000,00
			- , 	Quantit	ty	Unit Price	Fact.	- Anna	Total	
			Installation	1.	.00 x	8,000.00 x	1.0000	=	8,000.00	· · · · · · · · · · · · · · · · · · ·
19001	1283			LS F	REMOVE SH	ORING IN TAN	K(1-2-14/	<i>A</i>)	,	4,000.00
	,			Quantil		Unit Price	Fact.		Total	
			Installation		.00 x	4,000.00 x	1.0000	=	4,000.00	
19001	1284			LS F	RE-INSTALI	MECH. AGITA	TOR(1-2-	·14A)	and the second s	4,000.00
				Quanti		Unit Price	Fact.		Total	- 10 10 10 10 10 10 10 10 10 10 10 10 10
			Installation		.00 x	4,000.00 x	1.0000	=	4,000.00	
	····		Installation	1	.00 x	4,000.00 x	1.0000	-	4,000.00	

Cost Estimate

City Of Chicago Estimate 01-02-014A SWPP- TANK RELINING(REPAIR TANK ROOF SLAB)

Sect.	ltem	Mod.	Source	UOM Descrip	tion			Line Total
19001	1285	la contracione de la		LS REMOV	E AND DISPOSE OF	DEBRIS(1-2-14A)		2,000.00
				Quantity	Unit Price	Fact.	Total	· · · · · · · · · · · · · · · · · · ·
			Installation	1.00 x	2,000.00 x	1.0000 =	2,000.00	
19017	1001	•		LS INSTALI	4,000.00			
				Quantity	Unit Price	Fact.	Total	
			Installation	1.00 x	4,000.00 x	1.0000 =	4,000.00	
Subto	otal fo	1 =	ARTEK DIRROGERIOREANIZATANICEER REGERIOREZH	NESCESSIONAL PARAMETER PROPERTY OF THE STATE		la de constante de c	uuraupassa puun kanna kann	40,000.00
Estin	mate	Total	en e	KENTERENTERENTERENTERENTERENTERENTERENTE	CORDICATION AND AND STATE CONFIDENCE CONTRACTION OF A STATE CONTRACT	e can constitue a a social constitue de canada con constitue de canada de canada de canada de canada de canada Mandra constitue de canada de	en de la companya de La companya de la co	40,000.00

	ATTACHMENT A
(Chem	ical Tank Relining-Additional Workscope(Roof Slab Repair))
Project	Number: 01-02-014a Department: Water
Project	Manager: Richard Patrick Telephone Number: 744-5067
	UTILIZING JOC FOR CITY CONSTRUCTION PROJECTS
For all 3, 4 an	proposed projects please complete items 1 and 2 below. As appropriate, complete items d 5.
	(Attach to the MOA)
1.	Please describe the major features of the project:
Andrew Control of the	See Attached Memo Authorization Letter.
2.	Please explain why this project could not be bid using the City's traditional bid process and the need to use the JOC procurement system:
	The existing roof slab was investigated and found to have reached the end of its' useful service life. The slab must be replaced immediately or a sudden collapse could occur at any time.
3.	If this project is a one trade project, please provide additional explanation of why it would be in the City's best interest to do the project under JOC:
No. of the state o	N/A
4.	If it is anticipated that over 25% of the project will be non-prepriced, please provide an explanation on why JOC should be used:
	N/A
5.	If some elements of the proposed JOC project scope of work are covered by City Term Agreements, these elements should be removed from the JOC project scope of work. If it is not desirable to do so, please explain:
	N/A